PURAFIL ENVIRONMENTAL CORROSIVITY REPORT

10-Jun-2010

Company: 111063

Room Area ID: Reference #:



 Sales Order #:
 C002697

 CCC Panel #:
 P67968

 Date In:
 21-May-2010

 Date Out:
 03-Jun-2010

Days In Service: 13

CCC Panel # P67968

ISA Class G1 Mild

Copper Corrosion 138 Å/30 Days

Silver Corrosion 273 Å/30 Days

(see next page for complete analysis)

Summary for PURAFIL CCC # P67968

The electrolytic reduction analysis on Corrosion Classification Coupon #P67968 shows the presence of only very low concentrations of contaminants in the environment tested. The hydrogen sulfide level is not expected to exceed 3 ppb and the sulfur dioxide level should be less than 10 ppb. Corrosion is not a factor in determining equipment reliability in this environment.

Your local representative for additional information and assistance is:

Environmental Health and Eng

117 Fourth Avenue, Needham MA 02494, USA

tminegishi@eheinc.com

Purafil, Inc. / 2654 Weaver Way, Doraville GA 30340 USA / (770) 662-8545 / (770) 263-6922 Email: purafil@purafil.com / Internet: http://www.purafil.com

Displaying Page 1 Display Page 2


1 of 1 6/11/2010 9:38 AM

PURAFIL CCC # P67968 Analysis Results

Corrosion Film Composition				Gold Coupon -
	30 Days	rojections <u>1 Year</u>	<u>5 Year</u>	Magnified 20x
Copper Films Cu ₂ S	0 Å	0 Å	0 Å	
Cu ₂ O	138 Å	182 Å	238 Å	
Unknowns	0 Å	0 Å	0 Å	
Totals	138 Å	182 Å	238 Å	
Silver Films		•		
AgCI	0 Å	0 Å	0 Å	
Ag ₂ S	216 Å	2628 Å	13140 Å	
Unknowns	57 Å	694 Å	3469 Å	
Totals	273 Å	3322 Å	16609 Å	
Gold Pore Corrosion: Note: 1000 Å = 0.1 micron				

Equipment Reliability Correlation

(ISA Standard S71.04-1985 for Copper)



Displaying Page 2 <u>Display Page 1</u>

1 of 1 6/11/2010 9:38 AM